

SPRINGDALE FIRE DEPARTMENT

Fire Prevention Division

MONTHLY SPRINKLER FORM (OCCUPANT)

Date: _____

Inspector: _____

Below is a list of items required to be inspected monthly. A visual examination is necessary to insure that the equipment is ready for an emergency.

1. Fire Department Connections.

Location is unobstructed **Yes No**

Caps are in place **Yes No**

2. Control Valves

A total of _____ valves are on this system and were _____ open as required.

Closed valves were brought to the attention of a responsible person for corrective action on this date. **Yes No**

3. Pressure Gauges.

All pressure gauges were examined and found to be in proper operating condition.

Yes No

Improperly working gauges were brought to the attention of a responsible person for corrective action on this date. **Yes No**

Signature of person completing this form _____

Failing to conduct proper maintenance inspections and tests often results in damage and is also a violation of the State Fire Prevention Code. A licensed contractor of your choice in accordance with the rules and regulations of the Arkansas Fire Protection Board shall conduct annual tests and inspections.

Refer to quarterly test form for information regarding main drain tests, alarm function tests, and equipment tests for dry pipe sprinkler equipment.